



1. All sanitary sewer pipe must enter the building through the basement or crawl space side wall. Basement floor taps shall not be permitted.
2. 6" SDR 35 PVC pipe and fittings with premium joints shall be installed at 1% min. grade within 5' of the building. A 6" clean out shall be installed at the road right-of-way and a second just outside the wall. 4" sch 40 PVC pipe shall be installed through the wall with a cap on the inside.
3. All pipe shall be bedded with a minimum of 6" of #8 or #57 stone around all sides of the pipe.
4. No storm water shall enter the sanitary sewer at any point, which include but not limited to: sump lines, down spouts, yard drains, and catch basin's.
5. A Clay Dam is optional on a 6' section of solid pipe, no bell, if the water table is an issue in the trench.

REVISIONS			
NO.	DESCRIPTIONS	CHKD	DATE
1	C/O AT R.O.W.	MD	3/29/2017

DESIGNED BY:	MD
DRAWN BY:	MD
CHECKED BY:	TS

Typical Sanitary Sewer Lateral Detail

**SANITARY LATERAL DETAIL**

SCALE: NONE                      DATE: JAN. 2014

NORTHWESTERN WATER AND SEWER DISTRICT

12560 Middleton Pike  
P.O. Box 348  
Bowling Green, Ohio 43402  
Phone (419)-354-9090  
Fax (419)-354-9344

PROJECT NO:	
DRAWING NO.:	1 OF 1

P:\Projects\2017\Sanitary Sewer Lateral Detail.dwg